MONTH ENDING.

THE WELL MAINTANCE TRUCK W/ THE BOOM MOUNTED ON THE BACK NEED TO BE EXTENDED 7 ft. AT THIS TIME THE BOOMS HIGH PROHIBITS IT FROM BEING USE FOR WELL [redacted] PUMP INSTALATION. THE BOOM WAS PHOTO-GRAPHED & MEASURED TO SEE IF THERE IS A WAY OF EXTENDING THE BOOM. THIS INFORMATION WAS GIVEN TO AN ENGINEER NAMED ROY GAYLE. HE SPOKE W/ THE MANUFACTURES OF THE BOOM AND IT SEEMS THE BOOM CAN BE EXTENTED NO PROBLEM. ROY DREW UP SOME PLANS FOR THE BOOM EXTENTION. THESE PLANS WERE GIVEN TO CHUCK TO HAVE THE WORK DONE ON THE BOOM.

A GENERATOR WAS FOUND THAT CAN BE USED TO DRIVE THE 7.5, 5.5 HP PUMPS. THE ATMOSPHERIC PEOPLE HAVE ONE THAT WE CAN USE. THE GENERATOR NEEDS TO BE TOWED HERE FROM THE 200 AREAS. A ARMY TYPE HITCH IS NEEDED TO DO THIS.

WELL DRAW DOWN PLOTS AND THE WELL TEST COMPUTER PROGRAMS WERE INSTALLED UNDER MY UIC AT THE PSL BUILDING. PUMP TEST DATA CAN NOW BE RUN AT ANY TIME. THE PROGRAM PLOTS HARD COPY ON THE PLOTTING UNIT IN COG LOG, THIES TYPE CURVE FITS, STRAIGHT LINE PLOTS

THE GSA MEETING WAS ATTENDED IN LAST WEEK OF THE MONTH