Project Number _____

Battelle
Pacific Northwest Laboratories

Internal Distribution

JE Choate
PA Eddy
KR Heid
KR Price
Section Managers
FILE/LB

Date July 23, 1984

To Doug Carlisle

From P. Bramson for Harold Larson

Subject Facilities Cleanout Project

Per your telephone request, the following list of cleanout projects is submitted for consideration. I have arranged them according to the priorities as I understand them from our discussion.

First Priority: Removal of excess installed equipment. (Ref: Memorandum from Lynn R. Eberhardt to Bill Glass/Harold Larson)

1. 318 Building Remove Miscellaneous Equipment at West End

   A roll up door and fume hood were removed from the west end of the 318 Building (near room 113) and miscellaneous controls, motors, fans and ductwork were not removed. These should be removed as they serve no purpose, degrade the buildings appearance, and cause confusion for maintenance personnel. (Repainting and wall repair will be required.)

2. 318 Building Remove Unused Wiring

   When the HTLTR reactor space was decommissioned and decontaminated insufficient funding was available to completely remove all unused power and control wiring. As a result considerable unmarked and unused wiring existed (primarily in the basement). This wiring causes maintenance and engineering confusion and should be removed to reduce hazards or risks associated with the electrical system. The extent of this work is difficult to ascertain.

   Estimated cost $3-20K, expense, (not funded or scheduled).

Second Priority: Move Equipment/Cleanup Areas of Facilities

1. 318-A

   Remove aerial photography viewing equipment to Equipment Pool or excess
   3 men, truck, 0.5 day.

Other Needs:

In addition to the above stated priority needs, the following items should be considered if funds remain.

1. Comprehensive list previously submitted by Jim Choate for the O&EP Department.

2. Met Tower Quonset - both ends of the Quonset leak badly.

PEB:gd
Attachment